LEOCH PU384V160(384V160Ah)

PU384V160



LEOCH Provides Safe and Efficient LFP Battery Solutions.

LEOCH PU series adopt high safety LFP cell, with intelligent BMS management system independently developed by LEOCH, safe and reliable, excellent performance, stability and reliability, suitable for three-phase UPS backup system.

Features


- · Safest lithium battery technology
- · Eco-friendly
- · 10 Years Designed service life
- · Can/RS485 Communication output for monitoring
- · Achieve up 32 BMU in cascade communication
- · Interal cell balancing, Passive equalization, the
- maximum equalization current up to 200 mA · High-precision cell voltage and temperature
- High-precision cell voltage and temperature acquisition: ±3 mV,±1°C
- · Fan control circuit and interface, realize heat dissipation inside the module

PACK Style




Peformar	nce da	ta				
Time(min)	5	10	15	20	30	60
Constant Power(kw)	450	330	270	203	139.2	72
Constant Current(A)	1200	960	640	480	320	160

Size







System specifications	
Case Material	SPCC
Cell Type	Prismatic LiFePO ₄
Terminal Type	M10
IP Grade	IP20

384V
160Ah
61.4KWh
<=3%/Month
50Ah
3000 times(1C/1C)
1000*600*2200
1000Kg

Charge performance	
Rated Charge Current	80A
Maximum Charge Current	160A
Rated Charge Voltage	336-414V
Balancing Voltage	>408V


ōmin	
330KW@10min	

Temperature and humidity		
Discharge Temperature	-10-55°C	
Charge Temperature	0-45°C	
Storage Temperature	-20-60°C	
Transportation Temperature	-20-60°C	
Operating Humidity	<=95%R.H	


Other	
Communication	CAN/RS485
Dry Contact	DI/DO
System Parallels	<=15
Screen	Optional
Thermal Management	Natural Cooling




Discharge Performance at 25°C




Charge and Discharge at 25°C,0.5C



Temperature effects on capacity at 1C



Cycle life with DOD at 25°C, 1C/1C



Cautions

- 1. Do NOT short circuit, crush or disassemble
- 2. Do NOT heat or incinerate.
- 3. Do NOT immerse in any liquid.
- 4. Store at 50% capacity. Recharge every 6 months. The storage area should be clean, cool, dry and ventilated
- 5. Disconnect charging source prior to connecting or disconnecting battery terminals.
- 6. Do NOT dispose of batteries in a fire as they can explode.
- 7. Do NOT open, alter, or mutilate batteries. Released electrolyte is harmful to skin and eyes. It may be toxic. 8. Do NOT mix different types and brands of lithium-ion batteries.
- 9. Do NOT dispose in trash, follow local regulations and manufacturer's instruction.
- 10. See installation instructions before connecting to the supply.
- 11. The battery cabinet receives power from more than one source. Disconnection of all DC sources is required to De-energize this unit before installing or servicing. Wait 5 minutes before opening the unit.
- 12.Do NOT install on or over combustible surfaces
- 13. Refer to manual before servicing
- 14.Do NOT touch bare terminals.



Rack PU384V160(S)*-2* S-with HMI , No S without HMI 2-Two wire system, No 2 Three -wire system